



APPROVED AS NOTED
 DATE: 6/19/92 B.R.# 207382
 FEE: 406.85 BY: J. J. Jank
 NOTIFY BUILDING DEPARTMENT AT 785-1802 8 AM TO 4 PM FOR THE FOLLOWING INSPECTIONS:
 1. FOUNDATION - TWO REQUIRED FOR POURED CONCRETE
 2. ROUGH - FRAMING & PLUMBING
 3. INSULATION
 4. FINAL - CONSTRUCTION MUST BE COMPLETE FOR CO
 ALL CONSTRUCTION SHALL MEET THE REQUIREMENTS OF THE N.Y. STATE CONSTRUCTION & ENERGY CODES NOT RESPONSIBLE FOR DESIGN OR CONSTRUCTION ERRORS

OCCUPANCY OR USE IS UNLAWFUL WITHOUT CERTIFICATE OF OCCUPANCY

**PLUMBER CERTIFICATION ON LEAD CONTENT BEFORE CERTIFICATE OF OCCUPANCY
 SOLDER USED IN WATER SUPPLY SYSTEM CANNOT EXCEED 2/10 OF 1% LEAD.**

UNDERWRITERS CERTIFICATE REQUIRED

PLUMBING ALL PLUMBING WASTE & WATER LINES NEED TESTING BEFORE COVERING

SITE PLAN
 SCALE 1" = 50'

1
 SITE PLAN
 KANEY RESIDENCE / FIRE RD.#3, ROCKY POINT RD, EAST MARIEN
 ROBERT T. BANILEY ARCHITECT / SCALE: 1" = 50' 9/15/92

